



220-240V
1PH -50 Hz

STARTING AMPS 1.7
RUNNING AMPS 0.75

OPTIONAL CONTROLS	
1.	LOW WATER TEMP. CUT OUT
2.	EXTERNAL THERMOSTAT
3.	REMOTE SPEED CONTROL
4.	SUMMER/WINTER SWITCH

NOTES:
 WHEN CONTROLS 2 &/OR 3 ARE FITTED REMOVE SPEED CONTROL LOOP A-C.
 A 3-SPEED MOTOR IS FITTED WHICH IS FACTORY PRE-SET AT MEDIUM SPEED FOR SRW & STOCKROOM UNITS, AND HIGH FOR DOWNFLOW UNITS.
 FOR BOOST SPEED REMOVE A-C LOOP & USE A-B.
 FOR LOW SPEED REMOVE A-C LOOP & USE A-D.

- NOTES:**
- FIELD WIRING SHOWN THUS: - - - - -
 - G/Y - GREEN/YELLOW
 - INTERNAL WIRES TO BS.4808 COPPER
24/0,2(0,75²mm)

REV.	MOD.NO.	DATE	DRN	CHKD	DRAWN	ANR	DIFFUSION ENVIRONMENTAL LTD. 47 Central Avenue, West Molesey, Surrey, KT8 2OZ Telephone 020-8783-0033. Fax 020-8783-0140	
2	MIN MOD	23-07-12	DD	CDS	DATE	28-02-00		TITLE WIRING DIAGRAM (STD.) LPHW FOR SRW 522/550 & DFW P30/P45/P60 & STOCKROOM UNITS
MODIFICATION							CHECKED RA	TITLE WIRING DIAGRAM (STD.) LPHW FOR SRW 522/550 & DFW P30/P45/P60 & STOCKROOM UNITS
							DATE 28-02-00	JOB STANDARD
							APP'D RA	DRG.NO. A3/10315
							DATE 28-02-00	
1	REQ 1933	28-02-00	ANR	RA	DATE	28-02-00		